



NFPA 25 Inspection Requirements Checklist

Inspection Requirements:

- A list of the sprinklers in the property must be posted in spare head cabinet
- Hydraulic placards must be visible and legible
- Annual functional test for hose valves
- General information signs must be inspected annually

Sprinkler Head Requirements:

- Standard sprinklers are to be laboratory tested at 50 years and every 10 years thereafter
- Fast-response sprinklers are to be laboratory tested at 20 years and every 10 years thereafter
- Dry heads must be laboratory tested at 15 years, and every 10 years thereafter

Call or visit USAFP at: 847-816-0050
www.usafireprotectioninc.com/